

<b>PRODUCT NAME:</b>	<b>Inferno-Lite® FRP-200</b>						
<b>PRODUCT CODE:</b>	FRP-200						
<b>PERFORMANCE TESTING:</b>	<p>Fire Rating: UL Labeled for 3/4 hour in 1 hour rated masonry and door openings. UL File # KCMZ.R13833</p> <p>Attack Resistance: Underwriters Laboratories 972</p>						
<b>CONSTRUCTION:</b>	Construction is proprietary. This is a clear product containing no wire glass.						
<b>THICKNESS:</b>	7/8" Nominal (.875")						
<b>WEIGHT:</b>	7.25 Lbs. / Square Foot						
<b>MAXIMUM SIZE:</b>	<p>100 square inches of clear opening</p> <p>Maximum width of clear opening: 10"</p> <p>Maximum height of clear opening: 33"</p>						
<b>APPLICABLE STANDARDS:</b>	<table border="0"> <tr> <td>ANSI Z97.1</td> <td>ASTM C 1349</td> </tr> <tr> <td>CPSC 16 CFR 1201 (Category I and II)</td> <td>UL 9</td> </tr> <tr> <td>ASTM C 1036</td> <td>UL 10B</td> </tr> </table>	ANSI Z97.1	ASTM C 1349	CPSC 16 CFR 1201 (Category I and II)	UL 9	ASTM C 1036	UL 10B
ANSI Z97.1	ASTM C 1349						
CPSC 16 CFR 1201 (Category I and II)	UL 9						
ASTM C 1036	UL 10B						
<b>SINGLE RESPONSIBILITY:</b>	Global Security Glazing products are covered by our Single Responsibility® Program that ensures one firm has handled and is accountable for all phases of manufacturing.						
<b>INSTALLATION:</b>	All glazing to be installed with UL classified Metacaulk 950 or Blazeseal joint treatment as manufactured by Metalines, Inc. to maintain UL label requirements. For general glazing guidelines refer to the Glass Association of North America (GANA) Glazing Manual 2004 or latest edition. Contact Global Security Glazing for publication GSG-23-03 "Glazing Guidelines" for further information. A glass bite of 1" is required.						